

PUE and WUE values for the following period: [01/09/2023 – 31/08/2024]

OVHcloud Datacenter location	PUE	WUE (L/kWh)	REF (%)	
ROUBAIX	1,29	0,39	100	☑
GRAVELINES	1,22	0,20	100	☑
STRASBOURG	1,21	0,50	100	☑
BEAUHARNOIS	1,25	1,33	100	☑
ERITH	1,26	0,21	100	☑
LIMBURG	1,24	0,35	100	☑
OZAROW	1,25	0,60	100	☑
VINT HILL	1,39	0,10	0	☑
HILLSBORO	1,35	0,53	100	☑

OVH Group	1,26	0,37	92
-----------	------	------	----

PUE measured as per ISO/IEC 30134-2, category 1 for Vint Hill, Hillsboro and Roubaix 1 & 2 (22% of Roubaix's energy consumption), category 2 for other measurements.

WUE measured as per ISO/IEC 30134-9, category 1

European Code of Conduct for Energy Efficiency in Data Centre participants listed [here](#)